



North Eastern Electric Power Corporation Ltd.
(A Government of India Enterprise)
An ISO 9001, 14001 & OHSAS 18001 Corporation

CONTRACT & PROCUREMENT CELL

Website-www.neepco.co.in , Email : jayanta_contracts@rediffmail.com
Phone: 03670-288241, Fax: 03670-288240

CORRIGENDUM (III) DATED 23/01/2018

to
LIMITED NOTICE INVITING TENDER
NO. 001/2017-18/KHEP/C & P/Dtd. 01.11.2017

For

Design, Engineering, Manufacturing, Testing, Supply, Delivery including Supervision of Installation & Commissioning of Stainless Steel Butterfly Valve along with Power Pack, Operating Mechanism, Local/Remote Control & Display/Annunciation Panel, etc. for 2 x 25 MW Khandong Power Station valve house, KHEP, NEEPCO Ltd., Umrongso, Dima Hasao, Assam.

The NORTH EASTERN ELECTRIC POWER CORPORATION LTD. invites limited tender from the selected contractors/firms for awarding the contract "Design, Engineering, Manufacturing, Testing, Supply, Delivery including Supervision of Installation & Commissioning of Stainless Steel Butterfly Valve alongwith Power Pack, Operating Mechanism, Local/Remote Control & Display/Annunciation Panel, etc. for 2 x 25 MW Khandong Power Station valve house, KHEP, NEEPCO Ltd., Umrongso, Dima Hasao, Assam" in a Single Stage-Two Bid System.

- Under Section-G (Technical Specification) following amendments shall be applicable.
 - Clause No.2 (Design and Construction Requirement) Sub Clause 2.3 (Valve Seals).
 - a) Both the seals in the valve disc are to be fixed to the Valve door, by suitable mechanism to effect 100% sealing when matched with the seat rings penstock in the shut off position against full upstream pressure.
 - b) Seals may be placed one in upstream and one in downstream or both in downstream.
 - c) The Seal Adjusting rings are to be designed in such a way that further tightening of the holding down bolts increase contact of the seal with seat ring.
 - d) The seals should be replaceable during maintenance and made of suitable elastomeric material
 - Clause No.13 (Spare).
 - a) The supplier should include a list of mandatory spares for the valve and the same is to be included in the offer and will be considered for evaluation purpose.

Receipt
U.O. No. 1404 - Date 26/2/18
O/o E. D. (IT)
NEEPCO Ltd., Shillong-3

b) The supplier should also incorporate list of recommended spares for next 5 (five) years of operation. Item-wise list of the same may be uploaded in the e-tendering portal.

• **Price Schedule under Section-H (page No.62 of 77) has been amended as under.**

➤ Column No. 2 (Scope of Works), Sl. No. 1 shall as under "Design, Engineering, Manufacturing, Testing, Supply & Delivery of New Stainless Steel Butterfly Valve along with Power Pack, Operating Mechanism, Local/Remote Control & Display/Annunciation Panel, etc. for 2 x 25 MW Khandong Power Station valve house, KHEP, NEEPCO Ltd., Umrongso, Dima Hasao, Assam.

Cost of mandatory spares (two sets of seals, one set of self lubricating bushes, 2 sets of holding down bolts for both seals, special tools and tackles, alongwith other spares if any) required for the valve may please be added alongwith the above rates.


➤ **Column No. 2 (Scope of Works), Sl. No. 3 may be considered as omitted.** Bidders are requested not to quote for the same and put zero value under that column

➤ Column No. 2 (Scope of Works), Sl. No. 4 may please be read as "Charges towards Supervision, Installation & Commissioning of New Stainless Steel Butterfly Valve along with Power Pack, Operating Mechanism, installation & commissioning of Local/Remote Control & Display/Annunciation Panel, laying of fibre optic cable between VH & CR and all other associated works etc."

• Bidders are requested to submit hardcopies of the following in a sealed envelope. This should reach to the tendering authority prior to the opening of Price Bid.

➤ Item-wise list of mandatory spares alongwith unit price.

Not to be published


Sr. Manager (E/M), C&P
KHEP, NEEPCO Ltd., Umrongso