



ISO9001-2008, 14001-2004,
OHSAS 18001-2007

नॉर्थ ईस्टर्न इलेक्ट्रिक पावर कॉर्पोरेशन लिमिटेड
North Eastern Electric Power Corporation Limited
भारत सरकार का उद्यम (A Govt. of India Enterprises)

संयंत्र प्रमुख का कार्यालय/ **OFFICE OF THE HEAD OF PLANT**
रंगानदी जल विद्युत संयंत्र :: RANGANADI HYDRO ELECTRIC PLANT
पो.ऑ. : रंगानदी प्रोजेक्ट P.O. : RANGANADI PROJECT
याजली, अरुणाचल प्रदेश / YAZALI, ARUNACHAL PRADESH-791119

PH. No. 03809-222206, FAX: 03809-222212, e-mail: contracts.rhep@gmail.com, CIN – U40101ML1976GOI001658

Corrigendum : 01 Dtd. 24.04.2017


against

Notice Inviting Tender No – 11 /16-17 Dtd. 30.03.17

In partial modification of above NIT No.11/16-17 for supply & Installation of High Voltage Insulating Mats, the following amendment has been made in the technical specification.

Location	As per NIT Clause	Amended Clause
Technical specification : Sec-IV Sl.No. 4 : Materials, Tests and Test Certificates: (a & j)	High Dielectric Strength up to 65 KV	High Dielectric Strength up to 30 KV
Technical specification : Sec-IV Sl.No. 4 : Materials, Tests and Test Certificates: (m)	Insulating mat should be 100% shock proof with leakage current of less than 10mA at 22KV	Insulating mat should be 100% shock proof with leakage current of less than 10mA at 10 KV

All other terms & conditions of the NIT shall remain unchanged.


Sr. Manager (E/M) C&P
O/o the Head of Plant,
RHEP, NEEPCO Ltd.,
43 km, Yazali, A.P.